



Rick Scott
Governor

H. Frank Farmer, Jr., M.D., Ph.D.
State Surgeon General

July 11, 2011

Mr. Ben Berteau
Infiltrator Systems, Incorporated
6 Business Park Road
P.O. Box 768
Old Saybrook, CT 06475

Dear Mr. Berteau:

This letter amends the July 8, 2011 letter with regard to the comments for the third listed tank.

We have reviewed the engineer's report by Mark Tyl revised July 6, 2011, and the additional information you provided regarding the proposed polypropylene tank in single and dual compartment configuration and in C3 and C4 configuration.

Per your request for treatment receptacle design approval and in consideration of the variance granted by the Department on July 05, 2011, these configurations of the treatment receptacle have been assigned approval numbers as follows:


Effective Capacity (gal)	Approval Number	Comments
1090	70-143-11D-C3	dual compartment polypropylene tank with internal two vertical stiffeners and baffle attached to stiffener
1090	70-143-11S-C3	single compartment polypropylene tank with internal two vertical stiffeners
1090	70-143-11D-C4	dual compartment polypropylene tank with internal two vertical stiffeners and six horizontal stiffeners, and baffle attached to stiffener
1090	70-143-11S-C4	single compartment polypropylene tank with internal two vertical stiffeners and six horizontal stiffeners

Florida Administrative Code (F.A.C.) 64E-6.013(2)(j), effective April 28, 2010 states:

The State Health Office's designated **approval number** for the tank, and the **effective capacity** of the tank in gallons shall be cast or stamped into the wall or permanently stenciled or decaled onto the wall at the inlet end, to begin within 6 inches of the top of the wall. All identifying marks shall be inscribed or affixed at the point of manufacture only. All information supplied in the legend shall be provided with a minimum of **two** inch high lettering.

Enclosed is a current copy of the updated tank approvals on record with our office for your company. Please review the records for accuracy. If you have any questions please contact Eberhard Roeder at (850) 245-4070.

Sincerely,


Gerald Briggs
Bureau Chief

GRB/er
Enclosure



Bureau of Onsite Sewage Programs
4052 Bald Cypress Way, Bin A08 • Tallahassee, Florida 32399-1713
Phone: (850) 245-4070 • Fax: (850) 922-6969 • <http://www.MyFloridaEH.com>

NOTICE OF RIGHTS TO APPEAL

A party whose substantial interest is affected by this order may petition for an administrative hearing pursuant to Sections 120.569 and 120.57, Florida Statutes. Such proceedings are governed by Chapter 28-106, Florida Administrative Code. A petition for a hearing must be in writing and must be received by the Agency Clerk for the Department within twenty-one (21) days from the receipt of this order. The address for the Agency Clerk is 4052 Bald Cypress Way, Bin # A02, Tallahassee, FL 32399-1703. The Agency Clerk's facsimile number is (850) 410-1448.

Mediation is not available as an alternative remedy.

Your failure to submit a petition for hearing within 21 days from receipt of this order will constitute a waiver of your right to an administrative hearing, and this order shall become a "final order".

Should this Order become a Final Order, a party who is adversely affected by it is entitled to judicial review pursuant to section 120.68, Florida Statutes. Review proceedings are governed by the Florida Rules of Appellate Procedure. Such proceedings may be commenced by filing one copy of a Notice of Appeal with the Agency Clerk of the Department of Health and a second copy accompanied by the filing fees required by law with the Court of Appeal in the appropriate District Court. The notice must be filed within 30 days of the rendition of the final order.