



NOTES:

1. NUMBER OF ROWS MAY VARY.
2. ROW AND SAND BED LENGTH MAY VARY.
3. SYSTEM SAND BED AREA WILL VARY WITH NATIVE SOIL LOADING RATE.
4. DEPTH OF TOPSOIL IN ACCORDANCE WITH STATE RULES.
5. A MINIMUM OF 6" OF SYSTEM SAND BELOW, 3" OVER AND 6" BETWEEN AES PIPES.



INFILTRATOR WATER TECHNOLOGIES, LLC
 4 BUSINESS PARK RD, OLD SAYBROOK, CT 06475
 WWW.INFILTRATORWATER.COM
 PHONE: (800) 221-4436 / EMAIL: INFO@INFILTRATORWATER.COM

Advanced Enviro-Septic®

MOUND SYSTEM SECTION

| | |
|-----------|------------|
| PART NO. | AES UNIT |
| DATE | 07/31/2024 |
| SCALE | 1:60 |
| SHEET NO. | 01 of 01 |