



**CROSS SECTION**

**SIDE VIEW**

**TABLE 3: ENVIRO-AIRE SPECIFICATIONS**

TREATMENT PLANT	TREATMENT CAPACITY (GPD)	TOTAL VOLUME (GAL.)	PRIMARY VOLUME (GAL.)	AERATION VOLUME (GAL.)	CLARIFIER VOLUME (GAL.)	BOD LOADING (LBS/DAY)
EA75	750	1,113	346	584	186	1.25

REV.	DATE	INITIALS
A	7/26/2022	KJ

**Delta Treatment Systems, LLC**  
 9125 COMAR DRIVE, WALKER, LA  
 (800) 219-9183

COPYRIGHT (C) 2022 DELTA TREATMENT SYSTEMS, LLC (DTS). INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND IS THE PROPERTY OF DTS. NO PART OF THIS DRAWING SHALL BE REPRODUCED, DISTRIBUTED, DISCLOSED, OR USED BY ANY PERSON OR ORGANIZATION, IN WHOLE OR IN PART, WITHOUT THE PRIOR WRITTEN PERMISSION OF DTS. THIS INFORMATION IS BASED ON SPECIFIC INPUT PARAMETERS AND IS FOR BUDGETARY OR PRELIMINARY USE ONLY. USE AND INTERPRETATION OF THIS INFORMATION AND DETERMINING THE APPLICABILITY TO A SPECIFIC PROJECT IS AT THE SOLE DISCRETION OF THE USER AND/OR THE ENGINEER OF RECORD.

IM-1530 WITH ENVIRO-AIRE EA75

---

CROSS SECTION AND SIDE VIEW

HORIZ. SCALE N.T.S.	PROJECT NO. N/A
VERT. SCALE N/A	DATE 09/16/2020
DRAWN BY JLK	DESIGNED BY DTS
DRAWING NO. N/A	SHEET NO. 01 of 01