


CROSS SECTION

- NOTES:**
IM-1530 WORKING VOLUME = 1,537 GAL.
1ST COMPARTMENT VOLUME = 475 GAL.
2ND COMPARTMENT VOLUME = 1,062 GAL.
DISTANCE FROM TRANSFER PIPE TO TANK BOTTOM = 23"
DISTANCE FROM BAFFLE TO INLET SIDE TANK WALL = 50"

NO.	DATE	INITIALS



Delta Treatment Systems, LLC

COPYRIGHT (C) 2021 DELTA TREATMENT SYSTEMS, LLC (DTS). INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND IS THE PROPERTY OF DTS. NO PART OF THIS DRAWING SHALL BE REPRODUCED, DISTRIBUTED, DISCLOSED, OR USED BY ANY PERSON OR ORGANIZATION, IN WHOLE OR IN PART, WITHOUT THE PRIOR WRITTEN PERMISSION OF DTS. THIS INFORMATION IS BASED ON SPECIFIC INPUT PARAMETERS AND IS FOR BUDGETARY OR PRELIMINARY USE ONLY. USE AND INTERPRETATION OF THIS INFORMATION AND DETERMINING THE APPLICABILITY TO A SPECIFIC PROJECT IS AT THE SOLE DISCRETION OF THE USER AND/OR THE ENGINEER OF RECORD.

**DELTA ECOPOD E50-NX
IN IM-1530**

TYPICAL INSTALLATION DETAILS

HORIZ. SCALE N.T.S.	PROJECT NO. P/N
VERT. SCALE N/A	DATE 08/28/2023
DRAWN BY JLK	DESIGNED BY DTS
DRAWING NO. C0.1	SHEET NO. 01 of 01

G:\Technical Resources\New\AD-LS\PRODUCTS\2023 - Delta Product\ECOPOD\MBSR\ECOPOD\IM-1530.dwg