



CROSS SECTION

SECTION A - A

TABLE 1: ELECTRICAL REQUIREMENTS

TREATMENT PLANT	E60N
COMPRESSOR	Delta Model 06
MOTOR FULL LOAD AMPS	4.8
MEASURED OPERATING WATTS	373
ELECTRICAL REQUIREMENTS	115 volt- single phase

TABLE 2: ECOPOD SPECIFICATIONS

TREATMENT PLANT	E60N
TREATMENT CAPACITY (GPD)	600
MIN. PRIMARY TANK VOLUME (GAL.)	600
REACTOR TANK VOLUME (GAL.)	916
MEDIA SIZE	6' X 2' X 2'
AIR REQUIREMENTS	14.4 CFM

NOTES

1. INSTALL TANK PER PRECASTER INSTRUCTIONS.
2. IF PRECAST DIMENSIONS ARE OUTSIDE THE MINIMUM DIMENSIONS, CONTACT DELTA FOR REVIEW.
3. FOR DESIGNS WITH TREATMENT CAPACITIES GREATER THAN 1,500 GPD, CONTACT DELTA FOR REVIEW.
4. OPTIONAL SCHEDULE 40 PVC INSERT INSTALLED TO RAISE ECOPOD TO INLET AND OUTLET HEIGHT REQUIREMENTS.

NO.	DATE	INITIALS
C	04/25/22	E.Aiv
D	08/02/22	KJ
E	08/25/22	KJ



Delta Treatment Systems, LLC

COPYRIGHT (C) 2021 DELTA TREATMENT SYSTEMS, LLC (DTS). INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND IS THE PROPERTY OF DTS. NO PART OF THIS DRAWING SHALL BE REPRODUCED, DISTRIBUTED, DISCLOSED, OR USED BY ANY PERSON OR ORGANIZATION, IN WHOLE OR IN PART, WITHOUT THE PRIOR WRITTEN PERMISSION OF DTS. THIS INFORMATION IS BASED ON SPECIFIC INPUT PARAMETERS AND IS FOR BUDGETARY OR PRELIMINARY USE ONLY. USE AND INTERPRETATION OF THIS INFORMATION AND DETERMINING THE APPLICABILITY TO A SPECIFIC PROJECT IS AT THE SOLE DISCRETION OF THE USER AND/OR THE ENGINEER OF RECORD.

**DELTA ECOPOD E60-NIM
INFILTRATOR IM-1060 SEPTIC TANK**

GENERAL ARRANGEMENT

HORIZ. SCALE N.T.S.	PROJECT NO. P/N
VERT. SCALE N/A	DATE 11/17/2021
DRAWN BY CGK	DESIGNED BY AOB
DRAWING NO. C0.1	SHEET NO. 01 of 01

G:\Technical Resources\New\22-IS-1-PRODUCTS\2505 - Delta Product\2022 Drawings\completed\ECOPOD in IM-series.dwg